

OCL Analytical Services

35 Goshen Turnpike

Bloomington, NY 12721

Phone (845) 733-1557 Fax (845) 733-1944

Fax

To: Tri-Valley CSD From: _____

Fax: 985-2507 Pages: 7 inc this

Phone: _____ Date: 11/4/16

Re: Lead Results CC: _____

Urgent For Review Please Comment Please Reply Please Recycle

• **Comments:**

320827
 320828
 320829
 320913

This facsimile transmission and any documents accompanying it may contain confidential and privileged information belonging to the sender. This information is intended only for the use of the individual or entity for which it is addressed. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or taking of any action in reliance on the contents of this information is strictly prohibited. If you have received this transmission in error, please notify us by telephone immediately and return the original transmission to us via the U.S. Postal Service.

If you have difficulty receiving this fax, please call (845) 733-1557

OCL Analytical Services

95 Goshen Turnpike
Bloomingburg NY 12721

Phone 845-733-1557
Fax 845-733-1944
Web oclanalytical.com

Certificate of Analysis

Tri-Valley Central School
Attn: J. Bell
34 Moore Hill Road
Grahamsville, NY 12740


Project
Date Received 10/6/2016
Date Complete 11/4/2016
Date Printed 11/4/2016

Sample Number 320913-01
Federal ID NY5202956
Description Tri-Valley Central School
Location Room #223
Sample Point Sink 4 Eye Wash

Date Sampled 10/06/16 6:00
Sampler J. Bell
Matrix Drinking Water

Test	Result	Units	Method	MCL	Prep Date	Test Date	Analysr	Qualifiers
PB								
Lead, Pb	0.0092	mg/L	EPA 200.8	0.015	10/31/16 11:00	10/31/16 4:57	EL	

EL = Analysis by Envirotest Laboratories #10142

Approved By 

Lisa McClinton
Lab Manager

The reported results relate only to the sample identified above

OCL Analytical Services

35 Goshen Turnpike
Bloomingburg NY 12721

Phone 845-733-1557
Fax 845-733-1944
Web oclanalytical.com


Certificate of Analysis

Tri-Valley Central School
Attn: J. Bell
34 Moore Hill Road
Grahamsville, NY 12740

Project
Date Sampled 10/5/2016
Date Complete 11/4/2016
Date Printed 11/4/2016

Test	Result	Units	Method	MCL	Prep Date	Test Date	Initials	Qualifiers
320829-01	NY5202956	Tri-Valley Central School	Girls Locker Room Bear Side	Sink				Drinking Water
Lead, Pb	0.0035	mg/L	EPA 200.8	0.015	10/31/16 11:00	10/31/16 4:54	BL	
320829-02	NY5202956	Tri-Valley Central School	Girls Locker Room Bear Side	Water Fountain				Drinking Water
Lead, Pb	<0.0010	mg/L	EPA 200.8	0.015	10/31/16 11:00	10/31/16 4:55	BL	U
320829-03	NY5202956	Tri-Valley Central School	Girls Locker Room Office	Sink				Drinking Water
Lead, Pb	0.042	mg/L	EPA 200.8	0.015	10/31/16 11:00	10/31/16 4:55	EL	g
320829-04	NY5202956	Tri-Valley Central School	Boys Locker Room Office	Sink				Drinking Water
Lead, Pb	0.019	mg/L	EPA 200.8	0.015	10/31/16 11:00	10/31/16 4:56	EL	g

EL = Analysis by Envirotec Laboratories #10142

Approved By 
Lisa McClinton
Lab Manager

The reported results relate only to the samples identified above

Qualifiers
g = Result fails applicable drinking water standards
U = The analyte was analyzed for but not detected at or above the stated limit.

OCL Analytical Services

35 Goshen Turnpike
 Bloomingburg NY 12721

Phone 845-733-1557
 Fax 845-733-1944
 Web oclanalytical.com


Certificate of Analysis

Tri-Valley Central School
 Attn: J. Bell
 34 Moore Hill Road
 Grahamsville, NY 12740

Project
 Date Sampled 10/5/2016
 Date Complete 11/4/2016
 Date Printed 11/4/2016

Test	Result	Units	Method	MCL	Prep Date	Test Date	Initials	Qualifiers
320828-09	NY5202956	Tri-Valley Central School	Boy's Locker Room Kitchen Side			Sink R		Drinking Water
Lead, Pb	0.017	mg/L	EPA 200.8	0.015	10/31/16 11:00	10/31/16 4:49	EL	g
320828-10	NY5202956	Tri-Valley Central School	Boy's Locker Room Kitchen Side			Water Fountain		Drinking Water
Lead, Pb	0.0011	mg/L	EPA 200.8	0.015	10/31/16 11:00	10/31/16 4:50	EL	
320828-11	NY5202956	Tri-Valley Central School	Girl's Locker Room Kitchen Side			Sink		Drinking Water
Lead, Pb	0.0090	mg/L	EPA 200.8	0.015	10/31/16 11:00	10/31/16 4:51	EL	
320828-12	NY5202956	Tri-Valley Central School	Girl's Locker Room Kitchen Side			Water Fountain		Drinking Water
Lead, Pb	0.0066	mg/L	EPA 200.8	0.015	10/31/16 11:00	10/31/16 4:53	EL	

BL = Analysis by Envirotest Laboratories #1014Z

Approved By 
 Lisa McClinton
 Lab Manager

The reported results relate only to the samples identified above

Qualifiers

g = Result fails applicable drinking water standards

OCL Analytical Services

35 Goshen Turnpike
Bloomingburg NY 12721

Phone 845-733-1557

Fax 845-733-1944

Web odanalytical.com

Certificate of Analysis

Tri-Valley Central School
Attn: J. Bell
34 Moore Hill Road
Grahamsville, NY 12740

Project

Date Sampled 10/6/2016

Date Complete 11/4/2016

Date Printed 11/4/2016

Test	Result	Units	Method	MCL	Prep Date	Test Date	Initials	Qualifiers
320914-01 Lead, Pb	0.017	mg/L	EPA 200.8	0.015	10/31/16 11:00	10/31/16 4:58	EL	Drinking Water g
320914-02 Lead, Pb	0.020	mg/L	EPA 200.8	0.015	10/31/16 11:00	10/31/16 4:59	EL	Drinking Water g
320914-03 Lead, Pb	0.014	mg/L	EPA 200.8	0.015	10/31/16 11:00	10/31/16 4:59	EL	Drinking Water g
320914-04 Lead, Pb	0.019	mg/L	EPA 200.8	0.015	10/31/16 11:00	10/31/16 5:00	EL	Drinking Water g
320914-05 Lead, Pb	0.016	mg/L	EPA 200.8	0.015	10/31/16 11:00	10/31/16 5:02	EL	Drinking Water g
320914-06 Lead, Pb	0.037	mg/L	EPA 200.8	0.015	10/31/16 5:00	11/01/16 2:07	EL	Drinking Water g
320914-07 Lead, Pb	0.031	mg/L	EPA 200.8	0.015	10/31/16 11:30	10/31/16 5:03	EL	Drinking Water g
320914-08 Lead, Pb	0.031	mg/L	EPA 200.8	0.015	10/31/16 5:00	11/01/16 2:09	EL	Drinking Water g
320914-09 Lead, Pb	0.025	mg/L	EPA 200.8	0.015	10/31/16 5:00	11/01/16 2:10	EL	Drinking Water g