

OCL Analytical Services

**35 Goshen Turnpike
Bloomingburg, NY 12721**

Phone (845) 733-1557 Fax (845) 733-1944

Fax

H/S

*117 total
65 failed*

To: Tri Valley CSD From: _____

Fax: 985-2502 Pages: 13

Phone: _____ Date: 11/18/16

Re: Pb results CC: _____

Urgent For Review Please Comment Please Reply Please Recycle

• **Comments:**

OCL #5

320794 320799

320795 320800

320796

320797

320798

13 pages

This facsimile transmission and any documents accompanying it may contain confidential and privileged information belonging to the sender. This information is intended only for the use of the individual or entity for which it is addressed. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or taking of any action in reliance on the contents of this information is strictly prohibited. If you have received this transmission in error, please notify us by telephone immediately and return the original transmission to us via the U.S. Postal Service.

If you have difficulty receiving this fax, please call (845) 733-1557

OCL Analytical Services

35 Goshen Turnpike
 Bloomingburg NY 12721

Phone 845-733-1557
 Fax 845-733-1944
 Web oclanalytical.com

Certificate of Analysis


Tri-Valley Central School
 Attn: J. Bell
 34 Moore Hill Road
 Grahamsville, NY 12740

Project
 Date Sampled 10/4/2016
 Date Complete 11/18/2016
 Date Printed 11/18/2016

Test	Result	Units	Method	MCL	Prep Date	Test Date	Initials	Qualifiers
320794-01 Lead, Pb	NY5202956 0.11	Tri-Valley Central School mg/L	Room #172 EPA 200.8	0.015	10/30/16 8:00	Sink 10/31/16 12:50	EL	Drinking Water g
320794-02 Lead, Pb	NY5202956 0.046	Tri-Valley Central School mg/L	Room #172 EPA 200.8	0.015	10/31/16 10:00	Eye Wash Sink 11/01/16 1:31	EL	Drinking Water g
320794-03 Lead, Pb	NY5202956 0.62	Tri-Valley Central School mg/L	Lab for 171 and 172 EPA 200.8	0.015	10/31/16 10:00	Sink 11/01/16 1:33	EL	Drinking Water g
320794-04 Lead, Pb	NY5202956 0.94	Tri-Valley Central School mg/L	Lab for 171 and 172 EPA 200.8	0.015	10/31/16 10:00	Eye Wash 11/01/16 1:34	EL	Drinking Water g
320794-05 Lead, Pb	NY5202956 0.0017	Tri-Valley Central School mg/L	Theater Hall EPA 200.8	0.015	10/30/16 8:00	Water Fountain 10/31/16 12:51	EL	Drinking Water

EL = Analysis by Envirotec Laboratories #10142

Approved By



Lisa McClinton
 Lab Manager

The reported results relate only to the samples identified above

Qualifiers

g = Result fails applicable drinking water standards

OCL Analytical Services

35 Goshen Turnpike
 Bloomingburg NY 12721

Phone 845-733-1557
 Fax 845-733-1944
 Web oclanalytical.com

Certificate of Analysis

Tri-Valley Central School
 Attn: J. Bell
 34 Moore Hill Road
 Grahamsville, NY 12740

Project
 Date Sampled 10/4/2016
 Date Complete 11/18/2016
 Date Printed 11/18/2016

Test	Result	Units	Method	MCL	Prep Date	Test Date	Initials	Qualifiers
320795-01 Lead, Pb	NY5202956 0.0030	Tri-Valley Central School mg/L	7th Grade Boys Restroom EPA 200.8	0.015	10/30/16 8:00	Sink 10/31/16 12:52	EL	Drinking Water
320795-02 Lead, Pb	NY5202956 0.0081	Tri-Valley Central School mg/L	7th Grade Girls Restroom EPA 200.8	0.015	10/30/16 8:00	Sink 10/31/16 12:53	EL	Drinking Water
320795-03 Lead, Pb	NY5202956 0.25	Tri-Valley Central School mg/L	7th Grade Women's Restroom EPA 200.8	0.015	10/30/16 8:00	Sink 10/31/16 12:54	EL	Drinking Water g
320795-04 Lead, Pb	NY5202956 0.011	Tri-Valley Central School mg/L	H.S. Band Room EPA 200.8	0.015	10/30/16 8:00	Sink 10/31/16 12:54	EL	Drinking Water
320795-05 Lead, Pb	NY5202956 0.0097	Tri-Valley Central School mg/L	Room #165 EPA 200.8	0.015	10/30/16 8:00	Sink 10/31/16 12:55	EL	Drinking Water
320795-06 Lead, Pb	NY5202956 0.014	Tri-Valley Central School mg/L	Room #165 EPA 200.8	0.015	10/30/16 8:00	Fountain 10/31/16 12:57	EL	Drinking Water
320795-07 Lead, Pb	NY5202956 0.094	Tri-Valley Central School mg/L	Room #167 EPA 200.8	0.015	10/31/16 10:00	Sink 11/01/16 1:39	EL	Drinking Water g
320795-08 Lead, Pb	NY5202956 0.018	Tri-Valley Central School mg/L	Room #167 EPA 200.8	0.015	10/30/16 8:00	Fountain 10/31/16 12:58	EL	Drinking Water g
320795-09 Lead, Pb	NY5202956 0.098	Tri-Valley Central School mg/L	Room #169 EPA 200.8	0.015	10/31/16 10:00	Sink 11/01/16 12:13	EL	Drinking Water g

OCL Analytical Services

35 Goshen Turnpike
 Bloomingburg NY 12721

Phone 845-733-1557
 Fax 845-733-1944
 Web oclanalytical.com

Certificate of Analysis

Tri-Valley Central School
 Attn: J. Bell
 34 Moore Hill Road
 Grahamsville, NY 12740

Project
 Date Sampled 10/4/2016
 Date Complete 11/18/2016
 Date Printed 11/18/2016

Test	Result	Units	Method	MCL	Prep Date	Test Date	Initials	Qualifiers
320796-01 Lead, Pb	NY5202956 0.033	Tri-Valley Central School mg/L	Room #209 EPA 200.8	0.015	10/30/16 8:00	Sink 1 10/31/16 12:59	EL	Drinking Water g
320796-02 Lead, Pb	NY5202956 0.023	Tri-Valley Central School mg/L	Room #209 EPA 200.8	0.015	10/30/16 8:00	Sink 2 10/31/16 1:00	EL	Drinking Water g
320796-03 Lead, Pb	NY5202956 0.046	Tri-Valley Central School mg/L	Room #209 EPA 200.8	0.015	10/30/16 8:00	Sink 3 10/31/16 1:01	EL	Drinking Water g
320796-04 Lead, Pb	NY5202956 0.030	Tri-Valley Central School mg/L	Room #209 EPA 200.8	0.015	10/30/16 8:00	Sink 4 10/31/16 1:01	EL	Drinking Water g
320796-05 Lead, Pb	NY5202956 0.020	Tri-Valley Central School mg/L	H.S. 2nd Floor Girls Restroom EPA 200.8	0.015	10/30/16 8:00	Sink 10/31/16 1:02	EL	Drinking Water g
320796-06 Lead, Pb	NY5202956 0.013	Tri-Valley Central School mg/L	H.S. 2nd Floor Boys Restroom EPA 200.8	0.015	10/30/16 8:00	Sink 10/31/16 1:03	EL	Drinking Water
320796-07 Lead, Pb	NY5202956 0.080	Tri-Valley Central School mg/L	H.S. 2nd Floor by Room #209 EPA 200.8	0.015	10/30/16 8:00	Water Fountain 10/31/16 1:04	EL	Drinking Water g
320796-08 Lead, Pb	NY5202956 0.083	Tri-Valley Central School mg/L	H.S. 2nd Floor by Room #215 EPA 200.8	0.015	10/30/16 8:00	Water Fountain 10/31/16 1:04	EL	Drinking Water g

OCL Analytical Services

35 Goshen Turnpike
 Bloomingburg NY 12721

Phone 845-733-1557
 Fax 845-733-1944
 Web oclanalytical.com

Certificate of Analysis


Tri-Valley Central School
 Attn: J. Bell
 34 Moore Hill Road
 Grahamsville, NY 12740

Project
 Date Sampled 10/4/2016
 Date Complete 11/18/2016
 Date Printed 11/18/2016

Test	Result	Units	Method	MCL	Prep Date	Test Date	Initials	Qualifiers
320796-09 Lead, Pb	0.31	mg/L	EPA 200.8	0.015	10/30/16 8:00	10/31/16 1:07	EL	Drinking Water g
320796-10 Lead, Pb	0.14	mg/L	EPA 200.8	0.015	10/30/16 8:00	10/31/16 1:07	EL	Drinking Water g
320796-11 Lead, Pb	0.071	mg/L	EPA 200.8	0.015	10/30/16 8:00	10/31/16 1:11	BL	Drinking Water g
320796-12 Lead, Pb	3.1	mg/L	EPA 200.8	0.015	10/31/16 10:00	11/01/16 3:02	EL	Drinking Water g

EL = Analysis by Envirotest Laboratories #10142

Approved By



Lisa McClinton
 Lab Manager

The reported results relate only to the samples identified above

Qualifiers

g = Result fails applicable drinking water standards

OCL Analytical Services

95 Goshen Turnpike
Bloomingburg NY 12721

Phone 845-733-1557
Fax 845-733-1944
Web oclanalytical.com

Certificate of Analysis

Tri-Valley Central School
Attn: J. Bell
34 Moore Hill Road
Grahamsville, NY 12740

Project
Date Sampled 10/4/2016
Date Complete 11/18/2016
Date Printed 11/18/2016

Test	Result	Units	Method	MCL	Prep Date	Test Date	Initials	Qualifiers
320797-01	NY5202956	Tri-Valley Central School	Room #215			Sink 6		Drinking Water
Lead, Pb	0.15	mg/L	EPA 200.8	0.015	10/30/16 8:00	10/31/16 1:11	EL	g
320797-02	NY5202956	Tri-Valley Central School	Room #215			Sink 7		Drinking Water
Lead, Pb	0.19	mg/L	EPA 200.8	0.015	10/31/16 10:00	11/01/16 12:29	EL	g
320797-03	NY5202956	Tri-Valley Central School	Room #215			Sink 8		Drinking Water
Lead, Pb	0.14	mg/L	EPA 200.8	0.015	10/30/16 8:00	10/31/16 1:12	EL	g
320797-04	NY5202956	Tri-Valley Central School	Room #215			Sink 9		Drinking Water
Lead, Pb	0.056	mg/L	EPA 200.8	0.015	10/30/16 8:00	10/31/16 1:13	EL	g
320797-05	NY5202956	Tri-Valley Central School	Room #215			Sink 10		Drinking Water
Lead, Pb	0.60	mg/L	EPA 200.8	0.015	10/31/16 10:00	11/01/16 12:31	EL	g
320797-06	NY5202956	Tri-Valley Central School	Room #215			Sink 11		Drinking Water
Lead, Pb	0.079	mg/L	EPA 200.8	0.015	10/30/16 8:00	10/31/16 1:14	EL	g
320797-07	NY5202956	Tri-Valley Central School	Room #215			Sink 12		Drinking Water
Lead, Pb	0.58	mg/L	EPA 200.8	0.015	10/31/16 10:00	11/01/16 12:33	EL	g
320797-08	NY5202956	Tri-Valley Central School	Room #215			Sink 13		Drinking Water
Lead, Pb	0.070	mg/L	EPA 200.8	0.015	10/30/16 8:00	10/31/16 1:16	EL	g
320797-09	NY5202956	Tri-Valley Central School	Room #215			Sink 14		Drinking Water
Lead, Pb	0.065	mg/L	EPA 200.8	0.015	10/30/16 8:00	10/31/16 1:17	EL	g

OCL Analytical Services

35 Goshen Turnpike
Bloomingburg, NY 12721

Phone 845-733-1557
Fax 845-733-1944
Web oclanalytical.com


Certificate of Analysis

Tri-Valley Central School
Attn: J. Bell
34 Moore Hill Road
Grahamsville, NY 12740

Project
Date Sampled 10/4/2016
Date Complete 11/18/2016
Date Printed 11/18/2016

Test	Result	Units	Method	MCL	Prep Date	Test Date	Initials	Qualifiers
320797-10 Lead, Pb	NY5202956 0.16	Tri-Valley Central School mg/L	Room #217 EPA 200.8	0.015	10/30/16 8:00	Sink 1 10/31/16 1:17	EL	Drinking Water g
320797-11 Lead, Pb	NY5202956 0.13	Tri-Valley Central School mg/L	Room #217 EPA 200.8	0.015	10/30/16 8:00	Sink 2 10/31/16 1:18	EL	Drinking Water g
320797-12 Lead, Pb	NY5202956 0.091	Tri-Valley Central School mg/L	Room #217 EPA 200.8	0.015	10/30/16 8:00	Sink 3 10/31/16 1:19	EL	Drinking Water g

EL = Analysis by Envirotest Laboratories #10142

Approved By 
Lisa McClinton
Lab Manager

The reported results relate only to the samples identified above

Qualifiers
g = Result fails applicable drinking water standards

OCL Analytical Services

35 Goshen Turnpike
Bloomingburg NY 12721

Phone 845-733-1557
Fax 845-733-1944
Web oclanalytical.com

Certificate of Analysis

Tri-Valley Central School
Attn: J. Bell
34 Moore Hill Road
Grahamsville, NY 12740

Project
Date Sampled 10/4/2016
Date Complete 11/18/2016
Date Printed 11/18/2016

Test	Result	Units	Method	MCL	Prep Date	Test Date	Initials	Qualifiers
320798-01	NY5202956	Tri-Valley Central School	96 1st Floor Boys Restroom			Sink 1		Drinking Water
Lead, Pb	0.0026	mg/L	EPA 200.8	0.015	10/30/16 8:00	10/31/16 1:20	EL	
320798-02	NY5202956	Tri-Valley Central School	96 1st Floor Boys Restroom			Sink 2		Drinking Water
Lead, Pb	0.0068	mg/L	EPA 200.8	0.015	10/30/16 8:00	10/31/16 1:21	EL	
320798-03	NY5202956	Tri-Valley Central School	96 1st Floor Girls Restroom			Sink 3		Drinking Water
Lead, Pb	0.0066	mg/L	EPA 200.8	0.015	10/30/16 8:00	10/31/16 1:21	EL	
320798-04	NY5202956	Tri-Valley Central School	96 1st Floor Girls Restroom			Sink 1		Drinking Water
Lead, Pb	0.0076	mg/L	EPA 200.8	0.015	10/30/16 8:00	10/31/16 1:22	EL	
320798-05	NY5202956	Tri-Valley Central School	96 1st Floor Girls Restroom			Sink 2		Drinking Water
Lead, Pb	0.013	mg/L	EPA 200.8	0.015	10/30/16 8:00	10/31/16 1:23	EL	
320798-06	NY5202956	Tri-Valley Central School	96 1st Floor Boys Restroom			Sink 3		Drinking Water
Lead, Pb	0.0053	mg/L	EPA 200.8	0.015	10/30/16 8:00	10/31/16 1:23	EL	
320798-07	NY5202956	Tri-Valley Central School	96 1st Floor			Water Fountain		Drinking Water
Lead, Pb	<0.0010	mg/L	EPA 200.8	0.015	10/30/16 8:00	10/31/16 1:26	EL	U
320798-08	NY5202956	Tri-Valley Central School	H.S. Principal Office			Sink		Drinking Water
Lead, Pb	0.028	mg/L	EPA 200.8	0.015	10/30/16 8:00	10/31/16 1:27	EL	g

OCL Analytical Services

35 Goshen Turnpike
Bloomingburg NY 12721

Phone 845-733-1557
Fax 845-733-1944
Web oclanalytical.com

Certificate of Analysis


Tri-Valley Central School
Attn: J. Bell
34 Moore Hill Road
Grahamsville, NY 12740

Project
Date Sampled 10/4/2016
Date Complete 11/18/2016
Date Printed 11/18/2016

Test	Result	Units	Method	MCL	Prep Date	Test Date	Initials	Qualifiers
320798-09 Lead, Pb	NY5202956 0.013	Tri-Valley Central School mg/L	H.S. Library EPA 200.8	0.015	10/30/16 8:00	Sink 10/31/16 1:28	EL	Drinking Water
320798-10 Lead, Pb	NY5202956 0.0084	Tri-Valley Central School mg/L	H.S. Old Gym EPA 200.8	0.015	10/30/16 9:00	Water Fountain 10/31/16 1:28	EL	Drinking Water
320798-11 Lead, Pb	NY5202956 0.0054	Tri-Valley Central School mg/L	H.S. Women's Fac. Bathroom EPA 200.8	0.015	10/30/16 9:00	Sink 10/31/16 1:31	EL	Drinking Water
320798-12 Lead, Pb	NY5202956 0.018	Tri-Valley Central School mg/L	H.S. Men's Fac. Bathroom EPA 200.8	0.015	10/30/16 9:00	Sink 10/31/16 1:32	EL	Drinking Water g

EL = Analysis by Envirotec Laboratories #10142

Approved By



Lisa McClinton
Lab Manager

The reported results relate only to the samples identified above

Qualifiers

- g = Result fails applicable drinking water standards
- U = The analyte was analyzed for but not detected at or above the stated limit.

OCL Analytical Services

35 Goshen Turnpike
Bloomington NY 12721

Phone 845-733-1557
Fax 845-733-1944
Web oclanalytical.com

Certificate of Analysis

Tri-Valley Central School
Attn: J. Bell
34 Moore Hill Road
Grahamsville, NY 12740

Project
Date Sampled 10/4/2016
Date Complete 11/18/2016
Date Printed 11/18/2016

Test	Result	Units	Method	MCL	Prep Date	Test Date	Initials	Qualifiers
320799-01 Lead, Pb	NY5202956 0.061	Tri-Valley Central School mg/L	Room #217 EPA 200.8	0.015	10/30/16 9:00	Sink 10/31/16 1:34	EL	Drinking Water g
320799-02 Lead, Pb	NY5202956 0.0074	Tri-Valley Central School mg/L	2nd Floor 96 Girl's Restroom EPA 200.8	0.015	10/30/16 9:00	Sink 1 10/31/16 1:35	EL	Drinking Water
320799-03 Lead, Pb	NY5202956 0.0050	Tri-Valley Central School mg/L	2nd Floor 96 Girl's Restroom EPA 200.8	0.015	10/30/16 9:00	Sink 2 10/31/16 1:36	EL	Drinking Water
320799-04 Lead, Pb	NY5202956 0.0071	Tri-Valley Central School mg/L	2nd Floor 96 Girl's Restroom EPA 200.8	0.015	10/30/16 9:00	Sink 3 10/31/16 1:37	EL	Drinking Water
320799-05 Lead, Pb	NY5202956 <0.0010	Tri-Valley Central School mg/L	2nd Floor 96 EPA 200.8	0.015	10/30/16 9:00	Water Fountain 10/31/16 1:38	EL	Drinking Water U
320799-06 Lead, Pb	NY5202956 0.0055	Tri-Valley Central School mg/L	2nd Floor 96 Boy's Restroom EPA 200.8	0.015	10/30/16 9:00	Sink 1 10/31/16 1:38	EL	Drinking Water
320799-07 Lead, Pb	NY5202956 0.0056	Tri-Valley Central School mg/L	2nd Floor 96 Boy's Restroom EPA 200.8	0.015	10/30/16 9:00	Sink 2 10/31/16 1:39	EL	Drinking Water
320799-08 Lead, Pb	NY5202956 0.012	Tri-Valley Central School mg/L	2nd Floor 96 Boy's Restroom EPA 200.8	0.015	10/30/16 9:00	Sink 3 10/31/16 1:40	EL	Drinking Water

OCL Analytical Services

35 Goshen Turnpike
 Bloomingburg NY 12721

Phone 845-733-1557
 Fax 845-733-1944
 Web oclanalytical.com

Certificate of Analysis


Tri-Valley Central School
 Attn: J. Bell
 34 Moore Hill Road
 Grahamsville, NY 12740

Project
 Date Sampled 10/4/2016
 Date Complete 11/18/2016
 Date Printed 11/18/2016

Test	Result	Units	Method	MCL	Prep Date	Test Date	Initials	Qualifiers
320799-09 Lead, Pb	NY5202956 0.088	Tri-Valley Central School mg/L	EPA 200.8	0.015	10/30/16 9:00	10/31/16 1:41	EL	Drinking Water g
320799-10 Lead, Pb	NY5202956 0.055	Tri-Valley Central School mg/L	EPA 200.8	0.015	10/30/16 9:00	10/31/16 1:41	EL	Drinking Water g
320799-11 Lead, Pb	NY5202956 0.041	Tri-Valley Central School mg/L	EPA 200.8	0.015	10/30/16 9:00	10/31/16 1:44	EL	Drinking Water g
320799-12 Lead, Pb	NY5202956 0.029	Tri-Valley Central School mg/L	EPA 200.8	0.015	10/30/16 9:00	10/31/16 1:45	EL	Drinking Water g

EL = Analysis by Envirotest Laboratories #10142

Approved By



Lisa McClinton
 Lab Manager

The reported results relate only to the samples identified above

Qualifiers

- g = Result fails applicable drinking water standards
- U = The analyte was analyzed for but not detected at or above the stated limit.

OCL Analytical Services

35 Goshen Turnpike
 Bloomingburg NY 12721

Phone 845-733-1557
 Fax 845-733-1944
 Web oclanalytical.com


Certificate of Analysis

Tri-Valley Central School
 Attn: J. Bell
 34 Moore Hill Road
 Grahamsville, NY 12740

Project
 Date Sampled 10/4/2016
 Date Complete 11/18/2016
 Date Printed 11/18/2016

Test	Result	Units	Method	MCL	Prep Date	Test Date	Initials	Qualifiers
320800-10 Lead, Pb	NYS202956 0.0079	Tri-Valley Central School mg/L	EPA 200.8	Room #100 0.015	10/30/16 9:30	Sink 3 10/31/16 1:55	EL	Drinking Water
320800-11 Lead, Pb	NYS202956 0.060	Tri-Valley Central School mg/L	EPA 200.8	H.S. 1st Floor by Room 103 0.015	10/30/16 9:30	Water Fountain 10/31/16 1:56	EL	Drinking Water g
320800-12 Lead, Pb	NYS202956 0.012	Tri-Valley Central School mg/L	EPA 200.8	H.S. 1st Floor by Room 106 0.015	10/30/16 9:30	Water Fountain 10/31/16 1:57	EL	Drinking Water

EL = Analysis by Envirotest Laboratories #10142

Approved By 
 Lisa McClinton
 Lab Manager

The reported results relate only to the samples identified above

Qualifiers

g Result fails applicable drinking water standards

OCL Analytical Services

35 Goshen Turnpike
Bloomington NY 12721

Phone 845-733-1557

Fax 845-733-1944

Web oclanalytical.com

Certificate of Analysis

Tri-Valley Central School
Attn: J. Bell
34 Moore Hill Road
Grahamsville, NY 12740

Project

Date Sampled 10/4/2016

Date Complete 11/18/2016

Date Printed 11/18/2016

Test	Result	Units	Method	MCL	Prep Date	Test Date	Initials	Qualifiers
320800-01 Lead, Pb	NY5202956 0.13	Tri-Valley Central School mg/L	Room #113 EPA 200.8	0.015	10/31/16 10:00	Sink 11/01/16 12:34	EL	Drinking Water g
320800-02 Lead, Pb	NY5202956 0.065	Tri-Valley Central School mg/L	H.S. 1st Floor by 113 EPA 200.8	0.015	10/30/16 9:00	Water Fountain 10/31/16 1:45	EL	Drinking Water g
320800-03 Lead, Pb	NY5202956 0.037	Tri-Valley Central School mg/L	H.S. Guidance Office EPA 200.8	0.015	10/30/16 9:00	Sink 10/31/16 1:46	EL	Drinking Water g
320800-04 Lead, Pb	NY5202956 0.0053	Tri-Valley Central School mg/L	H.S. Fac LNG EPA 200.8	0.015	10/30/16 9:00	Sink 1 Bath 10/31/16 1:47	EL	Drinking Water
320800-05 Lead, Pb	NY5202956 0.011	Tri-Valley Central School mg/L	H.S. Fac LNG EPA 200.8	0.015	10/30/16 9:00	Sink 2 Kitchen 10/31/16 1:48	EL	Drinking Water
320800-06 Lead, Pb	NY5202956 0.015	Tri-Valley Central School mg/L	H.S. Fac LNG EPA 200.8	0.015	10/30/16 9:00	Sink 3 Seating Stairway 10/31/16 1:48	EL	Drinking Water
320800-07 Lead, Pb	NY5202956 0.054	Tri-Valley Central School mg/L	H.S. Fac LNG EPA 200.8	0.015	10/30/16 9:30	Sink 4 10/31/16 1:49	EL	Drinking Water g
320800-08 Lead, Pb	NY5202956 0.021	Tri-Valley Central School mg/L	Room #100 EPA 200.8	0.015	10/30/16 9:30	Sink 1 DBC 10/31/16 1:54	EL	Drinking Water g
320800-09 Lead, Pb	NY5202956 0.0059	Tri-Valley Central School mg/L	Room #100 EPA 200.8	0.015	10/30/16 9:30	Sink 2 DBC 10/31/16 1:55	EL	Drinking Water

Tri-Valley Central School
Attn: J. Bell
34 Moore Hill Road
Grahamsville, NY 12740

Project
Date Sampled 10/4/2016
Date Complete 11/18/2016
Date Printed 11/18/2016

Test	Result	Units	Method	MCL	Prep Date	Test Date	Initials	Qualifiers
320795-10 Lead, Pb	NY5202956 0.036	Tri-Valley Central School mg/L	Room #169 EPA 200.8	0.015	10/31/16 10:00	Fountain 11/01/16 12:23	EL	Drinking Water g
320795-11 Lead, Pb	NY5202956 0.51	Tri-Valley Central School mg/L	Room #171 EPA 200.8	0.015	10/31/16 10:00	Sink 11/01/16 12:25	EL	Drinking Water g
320795-12 Lead, Pb	NY5202956 0.92	Tri-Valley Central School mg/L	Room #171 EPA 200.8	0.015	10/31/16 10:00	Eye Wash Sink 11/01/16 12:26	EL	Drinking Water g

EL = Analysis by Envirotest Laboratories #10142

Approved By



Lisa McClinton
Lab Manager

The reported results relate only to the samples identified above

Qualifiers

g = Result fails applicable drinking water standards

HS, GND Floor

OCL Analytical Services

35 Goshen Turnpike
Bloomingburg NY 12721

Phone 845-733-1557
Fax 845-733-1944
Web oclanalytical.com

Certificate of Analysis

Tri-Valley Central School
Attn: J. Bell
34 Moore Hill Road
Grahamsville, NY 12740


Project
Date Received 10/6/2016
Date Complete 11/4/2016
Date Printed 11/4/2016

Sample Number 320913-01
Federal ID NY5202956
Description Tri-Valley Central School
Location Room #223
Sample Point Sink 4 Eye Wash

Date Sampled 10/06/16 6:00
Sampler J. Bell
Matrix Drinking Water

Test	Result	Units	Method	MCL	Prep Date	Test Date	Analyst	Qualifiers
PB								
Lead, Pb	0.0092	mg/L	EPA 200.8	0.015	10/31/16 11:00	10/31/16 4:57	EL	

EL = Analysis by Envirotest Laboratories #10142

Approved By 
Lisa McClinton
Lab Manager

The reported results relate only to the sample identified above

OCL Analytical Services

35 Goshen Turnpike
Bloomingburg NY 12721

Phone 845-733-1557
Fax 845-733-1944
Web oclanalytical.com

Certificate of Analysis

Tri-Valley Central School
Attn: J. Bell
34 Moore Hill Road
Grahamsville, NY 12740

Project
Date Sampled 10/5/2016
Date Complete 11/4/2016
Date Printed 11/4/2016

Test	Result	Units	Method	MCL	Prep Date	Test Date	Initials	Qualifiers
320827-01 Lead, Pb	0.0049	mg/L	EPA 200.8	0.015	10/31/16 10:30	10/31/16 4:28	EL	Drinking Water
320827-02 Lead, Pb	0.0061	mg/L	EPA 200.8	0.015	10/31/16 10:30	10/31/16 4:29	EL	Drinking Water
320827-03 Lead, Pb	0.0062	mg/L	EPA 200.8	0.015	10/31/16 10:30	10/31/16 4:30	EL	Drinking Water
320827-04 Lead, Pb	<0.0010	mg/L	EPA 200.8	0.015	10/31/16 10:30	10/31/16 4:31	EL	Drinking Water U
320827-05 Lead, Pb	0.0037	mg/L	EPA 200.8	0.015	10/31/16 10:30	10/31/16 4:32	EL	Drinking Water
320827-06 Lead, Pb	0.030	mg/L	EPA 200.8	0.015	10/31/16 10:30	10/31/16 4:32	EL	Drinking Water
320827-07 Lead, Pb	0.0061	mg/L	EPA 200.8	0.015	10/31/16 10:30	10/31/16 4:35	EL	Drinking Water
320827-08 Lead, Pb	0.0052	mg/L	EPA 200.8	0.015	10/31/16 10:30	10/31/16 4:35	EL	Drinking Water

V - Benchmark Center Valley ELAP 11827
A - Benchmark Sayre ELAP 11216

OCL ELAP 10510

OCL Analytical Services

35 Goshen Turnpike
 Bloomingburg NY 12721

Phone 845-733-1557
 Fax 845-733-1944
 Web oclanalytical.com

Certificate of Analysis

Tri-Valley Central School
 Attn: J. Bell
 34 Moore Hill Road
 Grahamsville, NY 12740

Project
 Date Sampled 10/5/2016
 Date Complete 11/4/2016
 Date Printed 11/4/2016

Test	Result	Units	Method	MCL	Prep Date	Test Date	Initials	Qualifiers
320828-01 Lead, Pb	NY5202956 0.012	Tri-Valley Central School mg/L	EPA 200.8	0.015	10/31/16 10:30	Room #010 Classroom Sink 1 10/31/16 4:39	EL	Drinking Water
320828-02 Lead, Pb	NY5202956 0.038	Tri-Valley Central School mg/L	EPA 200.8	0.015	10/31/16 10:30	Room #010 Workshop Sink 2 10/31/16 4:40	EL	Drinking Water
320828-03 Lead, Pb	NY5202956 0.0059	Tri-Valley Central School mg/L	EPA 200.8	0.015	10/31/16 11:00	Main Gym Bear Side Water Fountain 10/31/16 4:41	EL	Drinking Water
320828-04 Lead, Pb	NY5202956 0.011	Tri-Valley Central School mg/L	EPA 200.8	0.015	10/31/16 11:00	Main Gym Kitchen Side Water Fountain 10/31/16 4:45	EL	Drinking Water
320828-05 Lead, Pb	NY5202956 0.0040	Tri-Valley Central School mg/L	EPA 200.8	0.015	10/31/16 11:00	Boy's Locker Room Bear Side Sink L 10/31/16 4:46	EL	Drinking Water
320828-06 Lead, Pb	NY5202956 0.0026	Tri-Valley Central School mg/L	EPA 200.8	0.015	10/31/16 11:00	Boy's Locker Room Bear Side Sink R 10/31/16 4:47	EL	Drinking Water
320828-07 Lead, Pb	NY5202956 0.0013	Tri-Valley Central School mg/L	EPA 200.8	0.015	10/31/16 11:00	Boy's Locker Room Bear Side Water Fountain 10/31/16 4:48	EL	Drinking Water
320828-08 Lead, Pb	NY5202956 0.0067	Tri-Valley Central School mg/L	EPA 200.8	0.015	10/31/16 11:00	Boy's Locker Room Kitchen Side Sink L 10/31/16 4:49	EL	Drinking Water

OCL Analytical Services

35 Goshen Turnpike
Bloomingburg NY 12721

Phone 845-733-1557
Fax 845-733-1944
Web oclanalytical.com

Certificate of Analysis


Tri-Valley Central School
Attn: J. Bell
34 Moore Hill Road
Grahamsville, NY 12740

Project
Date Sampled 10/5/2016
Date Complete 11/4/2016
Date Printed 11/4/2016

Test	Result	Units	Method	MCL	Prep Date	Test Date	Initials	Qualifiers
320827-09 Lead, Pb	NY5202956 0.0034	Tri-Valley Central School mg/L	EPA 200.8	0.015	10/31/16 10:30	Room #012 Classroom Sink 1 10/31/16 4:36	EL	Drinking Water
320827-10 Lead, Pb	NY5202956 0.050	Tri-Valley Central School mg/L	EPA 200.8	0.015	10/31/16 10:30	Room #012 Photo Prep Sink 2 10/31/16 4:37	EL	Drinking Water g
320827-11 Lead, Pb	NY5202956 0.034	Tri-Valley Central School mg/L	EPA 200.8	0.015	10/31/16 10:30	Room #012 Dark Room Sink 3 10/31/16 4:38	EL	Drinking Water g
320827-12 Lead, Pb	NY5202956 0.047	Tri-Valley Central School mg/L	EPA 200.8	0.015	10/31/16 10:30	Room #012 Sink 4 Tower Sink 10/31/16 4:38	EL	Drinking Water g

EL = Analysis by Envirotest Laboratories #10142

Approved By



Lisa McClinton
Lab Manager

The reported results relate only to the samples identified above

Qualifiers

- g = Result fails applicable drinking water standards
- U = The analyte was analyzed for but not detected at or above the stated limit.

OCL Analytical Services

35 Goshen Turnpike
Bloomingburg NY 12721

Phone 845-733-1557

Fax 845-733-1944

Web oclanalytical.com


Certificate of Analysis

Tri-Valley Central School
Attn: J. Bell
34 Moore Hill Road
Grahamsville, NY 12740

Project
Date Sampled 10/5/2016
Date Complete 11/4/2016
Date Printed 11/4/2016

Test	Result	Units	Method	MCL	Prep Date	Test Date	Initials	Qualifiers
320829-01	NY5202956	Tri-Valley Central School						
Lead, Pb	0.0033	mg/L	EPA 200.8	0.015	10/31/16 11:00	10/31/16 4:54	EL	Drinking Water Side
320829-02	NY5202956	Tri-Valley Central School						
Lead, Pb	<0.0010	mg/L	EPA 200.8	0.015	10/31/16 11:00	10/31/16 4:55	EL	Drinking Water Side U
320829-03	NY5202956	Tri-Valley Central School						
Lead, Pb	0.042	mg/L	EPA 200.8	0.015	10/31/16 11:00	10/31/16 4:55	EL	Drinking Water Office g
320829-04	NY5202956	Tri-Valley Central School						
Lead, Pb	0.019	mg/L	EPA 200.8	0.015	10/31/16 11:00	10/31/16 4:56	EL	Drinking Water Office Sink g

EL = Analysis by Envirotec Laboratories #10142

Approved By 
Lisa McClinton
Lab Manager

The reported results relate only to the samples identified above

Qualifiers

- g = Result fails applicable drinking water standards
- U = The analyte was analyzed for but not detected at or above the stated limit.

OCL Analytical Services

35 Goshen Turnpike
 Bloomingburg NY 12721

Phone 845-733-1557
 Fax 845-733-1944
 Web oclanalytical.com


Certificate of Analysis

Tri-Valley Central School
 Attn: J. Bell
 34 Moore Hill Road
 Grahamsville, NY 12740

Project
 Date Sampled 10/5/2016
 Date Complete 11/4/2016
 Date Printed 11/4/2016

Test	Result	Units	Method	MCL	Prep Date	Test Date	Initials	Qualifiers
320828-09	NY5202956	Tri-Valley Central School	Boy's Locker Room Kitchen Side	0.015	10/31/16 11:00	Sink R 10/31/16 4:49	EL	Drinking Water g
Lead, Pb	0.017	mg/L	EPA 200.8					
320828-10	NY5202956	Tri-Valley Central School	Boy's Locker Room Kitchen Side	0.015	10/31/16 11:00	Water Fountain 10/31/16 4:50	EL	Drinking Water
Lead, Pb	0.0011	mg/L	EPA 200.8					
320828-11	NY5202956	Tri-Valley Central School	Girl's Locker Room Kitchen Side	0.015	10/31/16 11:00	Sink 10/31/16 4:51	EL	Drinking Water
Lead, Pb	0.0090	mg/L	EPA 200.8					
320828-12	NY5202956	Tri-Valley Central School	Girl's Locker Room Kitchen Side	0.015	10/31/16 11:00	Water Fountain 10/31/16 4:53	EL	Drinking Water
Lead, Pb	0.0066	mg/L	EPA 200.8					

EL = Analysis by Envirotec Laboratories #10142

Approved By 
 Lisa McClinton
 Lab Manager

The reported results relate only to the samples identified above.

Qualifiers
 g = Result fails applicable drinking water standards

OCL Analytical Services

35 Goshen Turnpike
 Bloomingburg NY 12721

Phone 845-733-1557
 Fax 845-733-1944
 Web oclanalytical.com

Certificate of Analysis

Tri-Valley Central School
 Attn: J. Bell
 34 Moore Hill Road
 Grahamsville, NY 12740

Project
 Date Sampled 10/6/2016
 Date Complete 11/4/2016
 Date Printed 11/4/2016

Test	Result	Units	Method	MCL	Prep Date	Test Date	Initials	Qualifiers
320914-01	NY5202956	Tri-Valley Central School	Theatre Ladies Room	Sink 1				Drinking Water
Lead, Pb	0.017	mg/L	EPA 200.8	0.015	10/31/16 11:00	10/31/16 4:58	EL	g
320914-02	NY5202956	Tri-Valley Central School	Theatre Ladies Room	Sink 2				Drinking Water
Lead, Pb	0.020	mg/L	EPA 200.8	0.015	10/31/16 11:00	10/31/16 4:59	EL	g
320914-03	NY5202956	Tri-Valley Central School	Theatre Ladies Room	Sink 3				Drinking Water
Lead, Pb	0.014	mg/L	EPA 200.8	0.015	10/31/16 11:00	10/31/16 4:59	EL	g
320914-04	NY5202956	Tri-Valley Central School	Theatre Ladies Room	Sink 4				Drinking Water
Lead, Pb	0.019	mg/L	EPA 200.8	0.015	10/31/16 11:00	10/31/16 5:00	EL	g
320914-05	NY5202956	Tri-Valley Central School	Theatre Ladies Room	Sink 5				Drinking Water
Lead, Pb	0.016	mg/L	EPA 200.8	0.015	10/31/16 11:00	10/31/16 5:02	EL	g
320914-06	NY5202956	Tri-Valley Central School	Theatre Men's Room	Sink 1				Drinking Water
Lead, Pb	0.037	mg/L	EPA 200.8	0.015	10/31/16 5:00	11/01/16 2:07	EL	g
320914-07	NY5202956	Tri-Valley Central School	Theatre Men's Room	Sink 2				Drinking Water
Lead, Pb	0.031	mg/L	EPA 200.8	0.015	10/31/16 11:30	10/31/16 5:03	EL	g
320914-08	NY5202956	Tri-Valley Central School	Theatre Men's Room	Sink 3				Drinking Water
Lead, Pb	0.031	mg/L	EPA 200.8	0.015	10/31/16 5:00	11/01/16 2:09	EL	g
320914-09	NY5202956	Tri-Valley Central School	Theatre Men's Room	Sink 4				Drinking Water
Lead, Pb	0.025	mg/L	EPA 200.8	0.015	10/31/16 5:00	11/01/16 2:10	EL	g

OCL Analytical Services

35 Goshen Turnpike
Bloomingburg NY 12721

Phone 845-733-1557
Fax 845-733-1944
Web oclanalytical.com


Certificate of Analysis

Tri-Valley Central School
Attn: J. Bell
34 Moore Hill Road
Grahamsville, NY 12740

Project
Date Sampled 10/6/2016
Date Complete 11/4/2016
Date Printed 11/4/2016

Test	Result	Units	Method	MCL	Prep Date	Test Date	Initials	Qualifiers
320914-10 Lead, Pb	NY5202956 0.0060	Tri-Valley Central School mg/L	EPA 200.8	0.015	10/31/16 11:30	Men's Sink 10/31/16 5:06	EL	Drinking Water
320914-11 Lead, Pb	NY5202956 0.027	Tri-Valley Central School mg/L	EPA 200.8	0.015	10/31/16 11:30	Ladie's Sink 1 10/31/16 5:07	EL	Drinking Water g
320914-12 Lead, Pb	NY5202956 0.12	Tri-Valley Central School mg/L	EPA 200.8	0.015	10/31/16 11:30	Ladies Sink 2 10/31/16 5:08	EL	Drinking Water g

EL = Analysis by Envirotest Laboratories #10142

Approved By 
Lisa McClinton
Lab Manager

The reported results relate only to the samples identified above

Qualifiers
g = Result fails applicable drinking water standards